

PROTOCOL FOR STORAGE OF FUEL AND OTHER HAZARDOUS FLUIDS

- During event days, only a working stock of fuel for one day may be present in the garage, awning or trailer. All other stock should remain in the fuel compound.
- The fuel should be stored in sealed containers, drums or cans.
- The working stock may not be located in the route of forklift trucks or other means of transport.
- The working stock may not exceed 400 liters and must be placed on a drip tray with a capacity of +10%.
- Two fire extinguishers with a minimum capacity of 6 liters and suitable for class B fires (liquid) must be present in direct surrounding of the storage.
- Presence of sufficient absorbents which can be used in case of spillage.

Each team is responsible for the drip trays, extinguishers, grit and absorbents.

A daily check will take place to ensure that each team meets all requirements.